



**General Submission Comments #1, We have revised our scope of work as follows. Reduce LED price signs to (1) marked as Sign A on plans. Reduce wall sign to (2) shown as Signs D1, D2 on plans.**

**#2, #3 Submission requirements. #4 See attached Public Works Confirmation form #5 Exceptions Findings; a,b,c.**

**19550 Stevens Creek Blvd., Cupertino, This 76 station has the same canopy image and LED type price sign we are requesting. The Chevron at the corner of De Anza and Stevens Creek has LED price sign and imaged canopy fascia. The Valero across the street has a LED price sign. #6 See attached corner and sidewalk site triangle diagram.**

**#7 Sign i, has been deleted from the scope of work.**

**#8 Sign Illumination a. see attached. b.c. Sign A and D1,D2 are equipped with dimming devices so light intensity can be regulated as needed. #9 see page (1) Ground sign location.**

**#10 Dark Sky Lighting Compliance. a. attached as page 1.b. see attached sign cut sheet and lighting information. c.the proposed Sign A is in a planter area and out of the site triangle.**

**Service station canopy standards. a. shown on page 5, LED's are recessed up into the light bar. b. no exterior fixtures are to be mounted to the canopy besides the 76 logos.c. see attached for canopy down lighter light intensity. d. this is covered in the above comment for 19550 Steven Creek, we are proposing like for like.**

**#11 being a new build all precautions have been addressed to protect the animals and birds in the construction area.**

**Project Data Comments. #12 See page (1) of plans. #13 proposing like for like canopy image.#14 See page (2) of plans.**

PERMIT DRAWINGS

03.28.23 R5 VT: REVISE SIGN I TO CUSTOMER PROVIDED DIMENSIONS PER JEFF STOCKTON, NO OTHER CHANGES. 03.17.23 R4 VT: REVISE SIGN I TO CUSTOMER PROVIDED ARTWORK PER JEFF STOCKTON, NO OTHER CHANGES. 02.03.23 R3 VT: REVISE SIGN I TO PANS ON BACKER PER JEFF STOCKTON, NO OTHER CHANGES. 11.15.22 R2 VT: ADD TECHNICAL SPECS TO RIGHT SIDE OF PAGE 2 PER STEVE LOCKE, NO OTHER CHANGES. 09.20.22 R1 VT: NUMEROUS CHANGES FOR SALES AND PERMITTING, ALL PER JEFF STOCKTON. 04.03.23 R6 VT: REMOVE REFERENCES TO BACKER PANEL FOR SIGN I, FOR PERMITTING, ALL PER JEFF STOCKTON. 09.06.23 R7 VT: ADD SITE MAP PG 2 W/ VISION TRIANGLE, VARIOUS REDLINES FOR PERMITTING, ALL PER JEFF STOCKTON. 09.06.23 R7 VT: ADD SITE MAP PG 2 W/ VISION TRIANGLE, VARIOUS REDLINES FOR PERMITTING, ALL PER JEFF STOCKTON. 03.26.24 R8 VT: VARIOUS UPDATES TO SITE MAP REMOVE CANOPY DOWNLIGHTER FROM PACKET, VARIOUS CLOUDED REDLINES FOR PERMITTING, ALL PER JEFF STOCKTON.

**SD SIGN DESIGNS** INCORPORATED

PO Box 4590 | 204 Campus Way Modesto Ca 95350 | O 209.524.4484 | F 209.521.0272 | Ca LIC#268001 | C-45 | Nv LIC#0082570 | C-6

<b>NOTICE TO THE CUSTOMER</b>		<b>CUSTOMER APPROVAL</b>		<b>DATE</b>		<b>BY</b>		<b>COMPANY OR JOB NAME / JOB DESCRIPTION</b>		<b>211239 R8</b>
<p>Note: The colors depicted on this rendering may not match actual colors used on the finished display. Please refer to the detail drawing for the approved color specifications. Note: The cost of providing electrical wiring to the sign area, all required permits and all special inspections are not included in this sign proposal. Note: The proportion of signs shown on building &amp; landscape area photos is an approximate representation.</p>		<input type="checkbox"/> ACCEPTED W/ NO CHANGES <input type="checkbox"/> ACCEPTED W/ CHANGES AS NOTED <input type="checkbox"/> REVISE AS NOTED AND RESUBMIT		08.17.22 VT    .24 VT 09.20.22 VT 11.15.22 VT 02.03.23 VT 03.17.23 VT 03.28.23 VT 04.03.23 VT 09.06.23 VT 03.26.24 VT		BY _____ CUSTOMER    BY _____ LANDLORD DATE _____    DATE _____		<b>76 SIGN PROGRAM</b> ADDRESS: <b>10490 SOUTH DE ANZA BOULEVARD CUPERTINO CALIFORNIA 95014</b> SALESPERSON: <b>JEFF STOCKTON</b> CUSTOMER CONTACT: <b>XXXXXX</b>		
<b>© 2024</b> This drawing was created to assist you in visualizing our proposal. The original ideas herein are the property of Sign Designs. Permission to copy or revise this drawing can only be obtained thru a written agreement w/ Sign Designs. See your sales representative or call Sign Designs.		By signing this drawing document, I understand that I am not obligated to purchase this project, notwithstanding the above artwork cannot be submitted for pricing, duplication and/or manufacturing to another sign company, architectural company or other business entity for the purpose or intent of manufacturing or for use as intellectual property, such as, but not limited to, a company logo, unless the represented logo was provided to Sign Designs by the customer and input into this drawing document by a Sign Designs employee.		NAME / DATE		I OF 6				

This sign is intended to be installed in accordance with the requirements of ARTICLE 600 of the national electrical code &/or other applicable codes. this includes proper grounding & bonding of the sign. The location of the disconnect switch after installation shall comply w/ ARTICLE 600.6(A)(1) of the National Electrical Code. All measures shown in this drawing are nominal until the "NOT FOR PRODUCTION" is removed