



CUPERTINO

**ADDENDUM NO. 1****Wilson Park Community Garden****PROJECT NO. 2020-01.1****Revised Bid Opening: December 6, 2022 - 2:00 P.M.****Issue Date: November 28, 2022**

The following revision is hereby made to the above referenced project.

1. The bid opening date and time for the Wilson Park Community Garden Project has been changed to **December 6, 2022, at 2:00 p.m.** All mentions of the original bid opening date and time in the bid documents shall hereinto be construed to refer to this new bid opening date and time.

The following questions have been received by the City. The City response is below each question.


1. Is there a place on site that you want the extra spoils from the excavation removed to or do they need to be off hauled?
  - a. Excavated material that will not be reused for the Project will need to be disposed of offsite.
2. The plans call for removing 1 to 2 feet of native to put the Hardware cloth/mesh underground. There is no stockpile location shown or specified on the plans. Where do we put all that dirt from removing and recompacting?
  - a. The City will work with the Contractor to identify nearby unplanted areas that are suitable for temporary stockpiling.
3. Please confirm that native material is suitable for compaction above the wire mesh.
  - a. The native material is to be reused to backfill above the wire mesh.
4. On the bid proposal line item 28 says landscape mulch. I don't see a call out on the plans for this? Line item 26 calls for mulch surfacing for below the planters which seems to have all the mulch covered. Please confirm where this is and what it entails?
  - a. Landscape mulch is to be used for shrub planting in the landscaped areas as shown in details 2/L5.0 and 3/L6.3.

5. Please confirm if the city will pay for the material testing, soil compaction testing, for this project?
- a. Per General Condition 7.8 (C) of the Project Manual, the City will bear the initial cost of inspection and testing to be performed by independent testing consultants retained by City.

Only questions received at a pre-bid meeting or in writing will be accepted for response. The deadline for questions has passed.

You must indicate receipt of this addendum on the last page of the Proposal. Failure to do so may cause rejection of your bid.

APPROVED BY:



Matt Morley  
Director of Public Works








# 2020-01.1 Wilson Park Comm Garden-Addendum 1

Final Audit Report

2022-11-28

Created:	2022-11-28
By:	Julia Kinst (juliak@cupertino.org)
Status:	Signed
Transaction ID:	CBJCHBCAABAAA7ZAnYqvPvhULiNf5Q9u5U1HXo_QGYrO

## "2020-01.1 Wilson Park Comm Garden-Addendum 1" History

-  Document created by Julia Kinst (juliak@cupertino.org)  
2022-11-28 - 11:52:55 PM GMT- IP address: 216.198.111.214
-  Document emailed to Matt Morley (mattm@cupertino.org) for signature  
2022-11-28 - 11:53:18 PM GMT
-  Email viewed by Matt Morley (mattm@cupertino.org)  
2022-11-28 - 11:58:02 PM GMT- IP address: 75.141.172.56
-  Document e-signed by Matt Morley (mattm@cupertino.org)  
Signature Date: 2022-11-28 - 11:58:34 PM GMT - Time Source: server- IP address: 75.141.172.56
-  Agreement completed.  
2022-11-28 - 11:58:34 PM GMT



Powered by  
**Adobe**  
**Acrobat Sign**